

Rezultati analize vode IZLAZ IZ FILTRA Veliki Grđevac 21.10.2015

| Parametar | Jedinica | MDK | |
|---------------------|------------------------------------|------|--------|
| Temperatura | °C | 25 | 14.5 |
| pH | | 9.5 | 7.58 |
| Otopljeni kisik | mg/L O ₂ | 2500 | 5 |
| Vodljivost | uS/cm | 2500 | 713 |
| Alkalitet | mg/L CaCO ₃ | >30 | 396 |
| Ukupna tvrdoća | mg/L CaCO ₃ | | 328 |
| Kalcijeva tvrdoća | mg/L CaCO ₃ | | 200 |
| Magnezijava tvrdoća | mg/L CaCO ₃ | | 128 |
| Permanganatni broj | mg/L O ₂ | 5 | 0.3 |
| UV254 | | | 0.0044 |
| Floridi | mg/L F ⁻ | 1.5 | 0.37 |
| Kloridi | mg/L Cl ⁻ | 250 | 1.7 |
| Nitriti - N | mg/L N | 0.15 | <0,01 |
| Nitrati - N | mg/L N | 11.3 | 0.448 |
| Fosfati | mg/L PO ₄ ⁻ | 0.92 | 0.26 |
| Sulfati | mg/L SO ₄ ²⁻ | 250 | 1.71 |
| Litij | mg/L Li ⁻ | | 0.023 |
| Natrij | mg/L Na ⁺ | 200 | 42.73 |
| Amonijak - N | mg/L N | 0.39 | <0,01 |
| Kalij | mg/L K ⁺ | 12 | 0.7 |
| Magnezij | mg/L Mg ²⁺ | | 34.3 |
| Kalcij | mg/L Ca ²⁺ | | 105.4 |
| Željezo | mg/L Fe | 0.2 | 0.018 |
| Mangan | mg/L Mn | 0.05 | 0.002 |